

HEPA Test Certificate

Leak scan testing report (reference EN ISO 29463-4:2018)



Filter Type

Model : HLA1113D215450E
Dimensions : 215x450x68 [mm]
Batch number : 202048
Product number : 310-400781264N050712

Nominal Technical Data

Air flow : 160 [m³/h]
Pressure drop : 120 [Pa]
Penetration integral value : ≤ 0,05 [%]
Penetration local value : ≤ 0,25 [%]
Filterclass : H13 [EN1822-1:2019]

Details of Test Parameters

Air flow : 160 [m³/h]
Flow velocity : 0,46 [m/s]
Test aerosol : DEHS
Mass concentration of test aerosol : 60-80 [mg/m³]

Testing Result

Product number : 310-400781264N050712
Model : HLA1113D215450E
Date : 2020 -11- 24
Quality checker : 1223

Approved : Yes No
☒ ☐ 1609

